



EST01 Wi-Fi Programmable Thermostat

Install and User Guide



1. Introduction -----	3
2. Install your Thermostat -----	6
3. Setup -----	8
3.1 Time setting-----	8
3.2 Working mode-----	9
3.3 Setup Wi-Fi-----	11
3.4 Schedule set-----	14
3.5 User setup-----	17
3.6 Factory set-----	20
3.7 Clean screen-----	27
3.8 Reset-----	27
4. Warranty -----	28
5. Regulatory info. -----	28

Appearance of the product may vary. Log in www.ecoer.com or ESS Pro App >**Files** >**Installation** to get the latest guide.

Features

- Compatible with most 24V controlled heating, cooling, and heat pump systems
- Set your temperature remotely from your smart phone
- Wi-Fi connectivity through App
- Work with Amazon Echo and Google Assistant
- 4.3” touch screen LCM display
- Quick connecting terminals to save installer’s time
- Be able to control fan speed of E Series Air Handlers for better dehumidification control
- 3-year limited warranty



Caution

ELECTRICAL HAZARD

Can cause electrical shock or equipment damage. Disconnect power before beginning installation.

EQUIPMENT DAMAGE HAZARD

Compressor protection is bypassed for Ecoer condensing units. **To prevent equipment damage, set compressor protection accordingly for other brand condensing units.**


MERCURY NOTICE

If this product is replacing a control that contains mercury in a sealed tube, do not place the old control in the trash. Contact your local waste management authority for instructions regarding recycling and proper disposal.

REQUIRED: 24 VAC POWER (“C” WIRE)

1. Introduction

Parts in the packaging box




Power supply	AC 24V
Temp. Setting range	50°F ~ 90°F
Display	Tempered touch sensitive screen
Dimensions (W x H x D)	4in. x 4in. x 0.79in.


Wiring Replacement Guide

Applied Model: Ecoer EAHATN-24/36/48/60 air handler

To get two-stage fan control for enhanced dehumidification, use the wiring in packaging box to replace the one already connected to CN9 terminal of indoor PCB.



Thermostat Layout



* The screen will wake up by touching the inside temperature area

Mode: Select system mode **OFF, COOL, AUTO, HEAT** and **EM HEAT**.

Fan: AUTO Runs based on working condition of the compressor.

ON: Keeps running all the time.

Adjust temperature: Touch **+** or **-** icon to set your desired temperature.

Menu (Back Button): Time setting, working mode, Wi-Fi, Schedule and other settings.


2. Install your Thermostat

Power off the system before remove your old thermostat.

Look at the wires going out of the wall and take a photo for reference. Label each wire going into your old thermostat with the provided stickers.

The EST01 Wi-Fi thermostat

- Does not work for 120-240V systems.
- Does not work with millivolt systems.
- Required 24 VAC power supply (“C” wire)
- Does not need jumpers because RC and RH are connected already.
- Does not support universal input (S terminals) for indoor and outdoor sensors.
- Does not support universal relay (U terminals) for ventilation.



EST01 Wi-Fi Thermostat


Mounting System

Screws

Anchors

Wall

Wiring Terminals in Mounting System




S: Single transformer
D: Double transformers

Terminal	Description
C	Common
RH / RC	24 VAC power (RH and RC are already connected each other)
O	Mode changeover
W2 (W)	Second stage heating or first stage auxiliary heat for heat pump systems
G	Fan for standard mode
Y1	Compressor
G2	Fan for dry mode
K	Reserved

3. Setup

3.1 Time Setting

- I. Press **Menu** at homepage, the screen will display **DATE TIME**.




- II. Press **Edit**, the screen displays **SETUP YEAR**, press + or - to change.
- III. Press **Next** to **SETUP MONTH / DATE / HOUR / MINUTE**, respectively.
- IV. Press **Done** to save time setting.

NOTE: Press **Menu** during setting will exit you directly and nothing will be saved.



3.2 Working Mode


- I. Press **Menu** at homepage, the screen will display **DATE TIME**, then press **Next** to **WORKING MODE**.



- II. Press **Edit**, the screen displays **HOLD**, press  or  to switch between **HOLD** and **SCHEDULE**.

- III. Press **Done** to save.

NOTE: Press **Menu** during setting will exit you directly and nothing will be saved.





HOLD: Keeps the desired temperature set all the time.

SCHEDULE: Follows 7-day plan (4 time periods per day) *

* To activate the scheduling, it's required to choose **AUTO** at thermostat homepage or on 'Ecoer Home' App control interface.

Activate 7-day Scheduling by Ecoer Home App

- Select Mode to **Auto**
- Turn ON Schedule (i.e. Choose 'Follow Schedule')




3.3 Setup Wi-Fi

Search 'Ecoer Home' on Google Play or App Store to install the App. Register with your phone number or email, log in App to add device.




- I. Press **Menu** at homepage, the screen will display **DATE TIME**, press **Next** twice to **SETUP WIFI**.



- II. Press **Edit**, the screen displays **SMART MODE***.

- III. Press **Done**, then Wi-Fi icon  will blink **90 seconds** on the upper-right corner.

*You may need to try **AP MODE** (Wireless Access Point) to connect device if **SMART MODE** does not work successfully.



Add device on 'Ecoer Home' App

- Press **+** icon (see [Fig.1](#)) on the upper-right corner of the App.
- Touch **“Confirm signal icon is blinking”** (see [Fig.2](#))
- Connect your smart phone to Wi-Fi (Select **2.4 GHz Wi-Fi** and input password), it takes 30 to 60 seconds to complete (see [Fig.3](#)). Touch **“Help”** to trouble shoot if you fail to make it online.




Fig. 1




Fig. 2




Fig. 3

*** The design of Ecoer Home App may subject to change.**

'Ecoer Home' App Control Interface

Display inside temperature

Display inside humidity

7-day scheduling (4 periods per day)

Settings

- Device ID
- Rename thermostat
- Temp. scale switch
- Firmware update

Set desired temp.

Change mode

Control fan

- On
- Auto
- **Circulate** indoor air when AC/HP stops


Schedule Status

- ON: Follow Schedule
- OFF: Hold On

*** The design of Ecoer Home App may subject to change.**

3.4 SCHEDULE SET

- I. Press **Menu** at homepage, the screen displays **DATE TIME**.
- II. Press **Next** until you see **SCHEDULE SET**.



- III. Press **Edit** to set detailed schedule (Below table shows the default desired temperature from Monday to Sunday).




Mon-Sun	Wake 06:00	Away 08:00	Home 18:00	Sleep 22:00
Desired Temp. in cooling	78F	85F	78F	82F
Desired Temp. in heating	70F	62F	70F	62F

- IV. See the following page for detailed schedule setup, press **Done** to save it.

NOTE: Press **Menu** during setting will exit you directly and nothing will be saved.

Detailed Schedule Setting from thermostat


- I. Press **+** or **-** to choose the day **1** of the week.
- II. Press **Next** to set from the first period **06:00** of the selected day, press **+** or **-** to adjust time **2** (15 minutes per interval).
 - a) Press **Next** to set desired **COOL** temperature **3** by press **+** or **-** icon.
 - b) Press **Next** to set desired **HEAT** temperature **4** by press **+** or **-** icon.
- III. Press **Next** to set schedule for other period of the selected day.





• • •

- IV. Continue to set schedule for other day of the week.
- V. Press **Done** to save.


Detailed Schedule Setting by 'Ecoer Home' App

- I. Click  to enter scheduling.
- II. Click the period you want to set, then scroll start Time, Cool Temp. and Heat Temp.
- III. Touch **"COMPLETE"** to save your settings.



3.5 USER SETUP






- I. Press **Menu** at homepage, the screen will display **DATE TIME**, then press **Next** until you see **USER SETUP**.



- II. Press **Edit** to enter into user setup interface.


Items	Range	Remarks
TEMP SCALE	F/C	Switch between Fahrenheit (Default) and Celsius
TEMP ADJ	-6F ~ 6F (Default 0F)	Adjust compensation for inside temperature
TEMP EFF	1F ~ 4F (Default 2F)	Adjust temperature difference between inside temp. and desired temp. to start COOL or HEAT
BRIGHTNESS	0 (Default)	Display current inside temperature and local time when screen sleeps
	1	Darken brightness but display all contents (never sleeps)
	2	The screen keeps the top brightness (never sleeps)
TIME SYNC	ON/OF	ON: Synchronize local time when connect Wi-Fi OF: Do not synchronize local time
FAN CIRC *	OF/05/15/30	OF: Turn off CIRC function (Default) 05: Turn on 5 minutes per hour 15: Turn on 15 minutes per hour 30: Turn on 30 minutes per hour

* Circulate the ventilation when Air Conditioner or Heat Pump stops for a long period.



NOTE: Press **Menu** during setting will exit you directly and nothing will be saved.

FAN CIRC Setting by Ecoer Home App




NOTE: App can set FAN CIRC* when Mode is Off (i.e. AC/HP stops).

* Circulate indoor air when Air Conditioner or Heat Pump stops for a long period.

3.6 FACTORY SET (Professional only)

- I. Press **Menu** at homepage, the screen will display **DATE TIME**, then press **Next** until you see **FACTORY SET**.



- II. Press **Edit**, the screen will display **SYSTEM TYPE** (See the following pages for details)

- III. Press **+** or **-** to set.



- IV. Press **Next** to set **COMP PROTECT** / **EM HEAT MODE** / **CHANGE OVER** as of required.

COMP PROTECT	Delay 0 (Default) ~ 10min to start the compressor
EM HEAT MODE	ON / OF (Default)
CHANGE OVER	Enable or Disable AUTO mode ON: HEAT or COOL switch automatically (Default)

- V. Press **Done** to save the setting.

NOTE: Press **Menu** during setting will exit you directly and nothing will be saved.

System Types List

Type	Descriptions	Application	Required Terminals
0	Cool only	ESI (AC only)	C, RC, Y1, G
1	W2	Gas or Oil Furnace	C, RH, W2, G
		Hot Water Boiler	C, RH, W2
2	Cool only + W2	ESI (AC only) + Furnace	C, RC, Y1, W2, G
3	Cool only	ESI + Air Handler	C, RC, Y1, O, G
4	Heat only	ESI + Boiler/(Furnace)	C, RH, Y1, *O, W2, (G)
5	Heat only (2 Stage)	No	C, RH, Y1, Y2 , O, *W2, G
6	1H/1C	ESI + Air Handler	C, RH, Y1, O, G, *W2
7	2H/1C	No	C, RH, Y1, Y2 , O, G, *W2
8	1H/1C	ESI + Air Handler	See following Pages
9	1H/1C (G/G2)	ESI + E series Air Handler	
10 (Default)	2H/1C	ESI + Air Handler ESI + Gas Furnace	
11	2H/1C (G/G2)	ESI + E series Air Handler	
12	Cool only (G/G2)	AC only + E series Air Handler	
13	Cool only (G/G2) + W2		


Remarks:

ESI- Ecoer Smart Inverter condensing unit

* means optional connection


Type 0 Cool Only

Ecoer variable speed air conditioner matches with indoor unit.




Type 2 Cool Only + W2 output

Ecoer variable speed air conditioner matches with gas or oil furnace.




Type 3 Cool Only

Ecoer variable speed heat pump matches with indoor unit.




Type 4 Heat Only + W2 output

Ecoer variable speed heat pump matches with furnace (G required) or boiler.




Type 6 1H/1C with constant indoor fan speed

Ecoer variable speed heat pump matches with G series air handler or other brand indoor unit.




Type 8 1H/1C with constant indoor fan speed

Ecoer variable speed heat pump matches with G series air handler or other brand indoor unit.




Type 9 1H/1C with two-stage fan control (G/G2) in cooling



Ecoer variable speed heat pump matches with E Series air handler



Type 10 2H/1C with constant indoor fan speed (Factory default)


Ecoer variable speed heat pump matches with indoor unit for 2 stage heating



Type 11 2H/1C with two-stage fan control (G/G2) in coolingEcoer variable speed heat pump matches with **E series air handler** and electric heater (Duel-fuel).**Type 12/13 Cool only with two-stage fan control (G/G2)**AC only (including Ecoer variable speed air conditioner) matches with **E Series air handler** (and electric heater - Type 13)

3.7 Clean Screen


- I. Press **Menu** at homepage, the screen will display **DATE TIME**, then press **Next** until you see **CLEAN SCREEN**.




- II. Press **Done** to allow the user to clean screen for 30 seconds without changing any settings.

3.8 Reset

- I. Press **Menu** at homepage, the screen will display **DATE TIME**, then press **Next** until you see **RESET**, press **Done** to enter.



- II. Press **+** or **-** to **ON**, then press **Done**. The thermostat will be reset to factory default settings.



4. Warranty

Ecoer warrants this product, against failure due to defect in materials or workmanship under normal use and maintenance, for a period of three (3) years. All warranty periods begin on the date of purchase by the consumer. If at any time during the warranty period the product is determined to be defective or malfunctions, Ecoer shall repair or replace it (at Ecoer's option).

Call Ecoer Support Hotline at **(855) 598-4093** or email support@ecoer.com if the product is defective. They will be able to make the determination whether the product should be brought back to the distributor you purchased from.

If deemed a warranty claim, distributor/dealer should log onto Ecoer's website www.ecoer.com and select File Claim in the Portal. Fill out required information and follow the prompts to submit.

This warranty does not cover removal or reinstallation costs. This warranty shall not apply if it is shown by Ecoer that the defect or malfunction was caused by damage which occurred while the product was in the possession of a consumer.

5. Regulatory information

FCC Certificate No.: GTI20191265C

This device conforms FCC Rules and Regulations under Part 15 Subpart B requirements. Operation is subject to the following two conditions:

- This device may not cause harmful interference.
- This device must accept any interference received, including interference that may cause undesired operation.

FCC Warning (USA only)

Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

©2017-2019 ECOER INC.

3900 Jermantown Rd., Suite 150, Fairfax, VA 22030

Tel: 703-348-2538

www.ecoer.com